P-12 Docking Platform Fire and Gas Mapping Report

Issue 01: 23rd April 2015

Prepared by INSIGHT NUMERICS OLIVER HEYNES



oheynes@insightnnumerics.com

INSIGHT NUMERICS | 51 Melcher Street 1st Floor, Boston, MA 02210, USA

Disclaimer

This report is an **example** of a typical fire and gas mapping report using Detect3D, produced for demonstration and marketing purposes only.

The work detailed in this report is purely an invention, and did not occur for an actual project. The geometry used is publically available.

Contents

Disclaimer	2
Introduction	4
Methodology	4
Software Description	4
Geometry Import	4
Detector Import from MS Excel	5
Flame Detector Field of View	6
Zone Definition	7
Coverage Calculation	
Performance Targets	9
Current Layout Coverage Results	9
Zone PZ-L-001	9
Flame Detector Coverage	9
Gas Detector Coverage	
Zone PZ-L-002	
Flame Detector Coverage	
Gas Detector Coverage	
Improved Coverage Layout and Results	15
Zone PZ-L-001	15
Flame Detector Coverage	15
Gas Detector Coverage	
Zone PZ-L-002	
Flame Detector Coverage	
Gas Detector Coverage	
Conclusions	20
Appendix A – Revised Flame Detector Layout Work Pack	21

Introduction

The P-12 platform is an offshore tanker docking station currently located at the client's facility in the Gulf of Oman. Originally installed in the early 1980's, the detection systems have been adjusted multiple times due to design changes and improvements. The client is now carrying out a full safety review of facilities in this area. As part of that review, fire and gas mapping is required for all offshore platforms including P-12. This report details the results of the assessment of the current detector layout, and provides recommendations for low-cost improvements.

Methodology

Software Description

The Fire and Gas Mapping was performed using the state-of-the-art software Detect3D developed by Insight Numerics. Detect3D is a widely used software product for Fire and Gas mapping, and has the advantage that it can interface directly with CAD. The primary technology of Detect3D is the highly accurate and fast ray-casting used for flame detector calculations. Both fire and gas detectors were considered in this study.

Geometry Import

Three-dimensional CAD files were available for this site from a recent review. The CAD was originally created in Aveva PDMS and output directly to a DGN file, which was read into Detect3D. The resulting geometry is shown in Figure 1 below. The original triangle count was 1.6 million triangles, but using Detect3D's mesh simplification techniques, this was reduced to just over 500,000 triangles.




Figure 1. A screenshot of Detect3D showing the P-12 geometry used in the project.

Detector Import from MS Excel

The locations and orientations for the fire and gas detectors were available in Microsoft Excel format. These were imported using Detect3D's Excel import tool. A plan view of the detector locations is shown below.




Figure 2. Plan view of the P-12 platform showing the locations of the flame detectors (unobstructed FOV shown in green for FD-009)




Figure 3. Plan view of the P-12 platform showing the locations of the point gas detectors

Flame Detector Field of View

The flame detector used on the P-12 is the Honeywell Analytics Fire Sentry SS-4 UV/IR flame detector. The specifications for the Field of View (FOV) were specified in the manual available online, and input into Detect3D as shown below. The sensitivity was set to HIGH, resulting in a maximum range of 65 feet with a wide viewing angle of 120° in both the horizontal and vertical planes. The FOV in Detect3D in the Flame Detector Model Viewer is shown below.




Figure 4. The Honeywell SS-4 detector FOV for a 1 ft² n-Heptane pan file




Figure 5. Three-dimensional view of the Honeywell SS-4 FOV in the Detect3D model for FD-009

Zone Definition

Two zones were identified on the platform for the coverage, and are show in plan view and perspective view below. The two zones are PZ-L-001 (yellow) and PZ-L-002 (orange).




Figure 6. Plan view of the P-12 platform showing the location of the two zones




Figure 7. The two zones in perspective view in Detect3D

Coverage Calculation

The calculation of coverage for both the flame and gas detectors was performed in Detect3D by filling each zone with a point cloud of 0.125 meter spacing. The software calculated the coverage of each point, and used this data to calculate volume-based coverage statistics.

A unique aspect of Detect3D is its ability to account for equipment volume. The software contains specialized algorithms to determine if points are inside, or outside, equipment. Point that are inside equipment do not count towards the coverage calculation – effectively, Detect3D does not penalize the detectors for not being able to cover volumes inside equipment.

An example of the equipment volume for PZ-L-001 is shown on the figure below. The purple volumes indicated where Detect3D calculated the points were inside equipment.




Figure 8. The equipment volume calculated in Detect3D for PZ-L-001

Accounting for the equipment volume reduced the total volume of PZ-L-001 from 355.8 m³ to 323.4 m³, and from 363.9 m³ to 320.2 m³ for PZ-L-002. Although the changes may seem small, they are, in fact, critical when attempting to achieve 90% coverage.

Performance Targets

The performance target set by the client's internal Fire and Gas Philosophy is as follows:

90% 100N coverage (one or more detectors)

50% 200N coverage (two or more detectors)

Current Layout Coverage Results

Zone PZ-L-001

Flame Detector Coverage

The flame detector coverage for Zone PZ-L-001 was calculated in Detect3D by performing ray casting for all the detectors imported from the original Excel spreadsheet. An example of the ray casting for one of the flame detectors is shown below. The resolution of the detectors was set to 1° with 2 adaptive refinements, resulting in an effective resolution of 0.25°. The typical computation time for a single detector was 3 seconds.




Figure 9. The obstructed FOV of FD-009 in Detect3D, generated from 148,000 rays (4 seconds computation time)

The flame detector coverage for the zone was calculated in Detect3D by filling the zone with a point cloud of 0.125 meter resolution, resulting in nearly 200,000 points for PZ-L-001. The visibility of each point was determined to each detector by calculating whether the point was within the obstructed FOV. The data for each point was then compiled into a statistical data set for the coverage of the zone. The results of the coverage assessment were output from Detect3D to Excel, and are shown below:

Fire Zone	Zero (0ooN)	1 or more (≥ 100N)	2 or more (≥ 200N)	3 or more (≥ 300N)
Zone PZ-L-001	16.2%	83.8%	45.5%	18.4%

As can be seen from the data, the detector layout **does not** comply with the required performance standard, as the 100N coverage is 83.8% (at least 90% coverage is required) and the 200N coverage is 45.5% (50% coverage required).

Note that the coverage given by Detect3D is volume-based, and is not dependent on the height of a plan under consideration.

The coverage of the zone can be visualized in two and three dimensions, using contours (shown at 2 meters height above the base of the zone in Figure 10 and isovolumes of zero coverage in Figure 11).




Figure 10. Flame detector coverage contour at 2 meters height above the zone base – color key shown at bottom-right

Both the coverage contours and isovolumes reveal the complex coverage of the detectors. The output also demonstrates the accuracy of Detect3D, and the software's ability to capture the details of the obstructions present on the platform to the detectors.




Figure 11. Zero-coverage isovolume for the flame coverage for Zone PZ-L-001.

Gas Detector Coverage

The gas detector coverage in PZ-L-001 was calculated using the "Design Gas Cloud" approach commonly used for standard similar to BP and Shell. This approach uses a spherical gas cloud of a certain diameter, at the LEL concentration, to determine the coverage. The coverage for each point in the zone is calculated by positioning the center of the gas cloud at that point, and calculating the number of detectors that would be in alarm.

For the purposes of the initial assessment, a gas cloud diameter of 5 meters has been used. Based on this gas cloud, the following gas detector coverage is calculated.

Gas Zone	Zero (0ooN)	1 or more (≥ 100N)	2 or more (≥ 200N)	3 or more (≥ 300N)
Zone PZ-L-001	20.9%	79.1%	40.2%	12.7%

Similar to the flame detector coverage, the gas detectors do not provide sufficient coverage to comply with the performance criteria at either the 100N or 200N coverage levels.

Coverage contours and isovolumes for the gas detectors are shown on Figure 12 and Figure 13 respectively.




Figure 12. Gas detector coverage contour at 2 meters height above the zone base - color key shown at bottom-right




Figure 13. Zero-coverage isovolume for the gas coverage for Zone PZ-L-001

Zone PZ-L-002

Flame Detector Coverage

The flame detector coverage for Zone PZ-L-002 was calculated in Detect3D as shown on the table below. The zone does not comply with the performance criteria for the 10oN or 20oN coverage.

Fire Zone	Zero (0ooN)	1 or more (≥ 100N)	2 or more (≥ 200N)	3 or more (≥ 3ooN)
Zone PZ-L-002	25.5%	74.5%	36.5%	12.9%

Coverage contours at a height of 2 meters above the base of the zone are shown below.

Figure 14. Flame detector coverage contour at 2 meters height above the zone base – color key shown at bottom-right

Gas Detector Coverage

The gas detector coverage for Zone PZ-L-002 indicates only 74.5% 100N coverage and 36.5% 200N coverage for the 5 meter diameter gas cloud. Coverage contours for the gas mapping are shown on Figure 15.

Gas Zone	Zero (0ooN)	1 or more (≥ 100N)	2 or more (≥ 200N)	3 or more (≥ 300N)
Zone PZ-L-002	39.5%	60.5%	10.6%	0.3%

insightnumerics

COVERAGE KEY Zero Coverage (0ooN) Coverage of 1 detector (1ooN) Coverage of 2 detectors (2ooN) Coverage of 3 detectors (3ooN) Coverage of 4 detectors (4ooN)




Figure 15. Gas detector coverage contour at 2 meters height above the zone base – color key shown at bottom-right

Improved Coverage Layout and Results

Zone PZ-L-001

Flame Detector Coverage

The Detector Ranking Tool was used on the original layout to determine the effectiveness of each detector. The tool operates by briefly switching off each detector in turn, and recording the reduction in coverage. Detectors that have little impact on coverage when switched off are less effectively positioned than those that have a large impact. The results are shown on the table below. The 100N and 200N coverage deficits are shown for each detectors, together with the ranking of those deficits and then the final ranking based on an 80/20 bias of the 100N and 200N.

)	Flame Detector Rankings for Zone PZ-L-001 🐡 🗕 🗖 🗙							
Zone:	Fire	Zone: Zone	PZ-L-001 ~	Final Ra	anking Bias: ≥			≥2ooN
No	tes	Detector	≥1ooN Deficit	≥2ooN Deficit	≥1ooN Rank	≥2ooN Rank	Weighted Rank	Final Rank
Be	st	FD-005	14.4	13.7	1	1	1	1
		FD-003	8.1	8.4	2	2	2	2
		FD-004	4	3.8	3	7	3.8	3
		FD-006	3.9	7.4	4	3	3.8	3
		FD-001	3.4	6.9	5	4	4.8	5
		FD-002	3.1	6.3	6	6	6	6
Wo	orst	FD-007	2.7	6.6	7	5	6.6	7




Figure 16. Results of the detector ranking tool on Zone PZ-L-001 showing best to least effective flame detectors

The ranking labels are shown in red on Figure 16, indicating the best and worst positioned detectors. This information was very useful as it indicated that in order to improve coverage, attention should be focused on repositioning FD-007, FD-002 and FD-001.

In order to improve coverage, poorly positioned detectors were first re-oriented in the azimuth and declination angles to make sure that the FOV covered the zone as effectively as possible. Often detectors were positioned with too high a declination, such that they were pointing towards the deck at too steep an angle to provide good coverage, or the azimuth angle pointed the detector away from the zone. Once this step was complete, the detector ranking tool was run several times, and the worst performing detectors were repositioned to provide better coverage. The new position was judged based on ease of installation and proximity to zero-coverage areas, as highlighted by the zero-coverage isovolume. If coverage could not be achieved from repositioning the detectors, new detectors would be added as a last resort.

For Zone PZ-L-001, flame detectors FD-001 and FD-002 were re-orientated, while flame detectors FD-004 and FD-007 were repositioned. No new detectors were required for the coverage of this zone. In fact, FD-004 was repositioned to improve coverage on the adjacent zone PZ-L-002. The updated locations are given in the Appendices of this report. The improved coverage is as follows:

Fire Zone	Zero (0ooN)	1 or more (≥ 100N)	2 or more (≥ 200N)	3 or more (≥ 300N)
Zone PZ-L-001	8.9%	91.1%	67.7%	37.5%

The coverage for PZ-L-002 is now compliant with the performance standard. The new layout of detectors is shown on Figure 17.




Figure 17. New flame detector layout for PZ-L-001

Gas Detector Coverage

The gas detector coverage for Zone PZ-L-001 was originally calculated using a 5 meter diameter gas cloud. However, closer inspection of the risk associated with the equipment in the zone resulted in a redefinition of the risk areas. The high risk zone, highlighted in red below, was marked separately from the lower risk zone, marked in purple. While a 5 meter diameter gas cloud was appropriate for the high risk areas, a 10 meter diameter gas cloud was instead used for the lower risk areas. This was achieved in Detect3D by adding a new risk grade ("Grade D") and setting the gas cloud diameter for the risk grade to 10 meters. Subsequently, two subzones were defined as shown in Figure 18, one at Risk Grade A (red) and the other at Risk Grade D (blue).




Figure 18. Gas Risk Zoning in PZ-L-001

The coverage for the subzones with the original placement of the detectors is now above 90% for the newly identified risk zones. As these are the only ones under consideration, this layout is deemed acceptable without any further changes.

Fire Zone	Zero (0ooN)	1 or more (≥ 100N)	2 or more (≥ 200N)	3 or more (≥ 3ooN)
Zone PZ-L-001	8.9%	91.9%	67.7%	37.5%
High Risk Sub-Zone	0.9%	99.1%	73.0%	28.7%
(Grade A. 5m cloud)				
Low Risk Sub-Zone	0.0%	100.0%	99.4%	56.1%
(Grade D, 10m cloud)				

Zone PZ-L-002

Flame Detector Coverage

The initial flame detector coverage for PZ-L-002 was relatively poor (only 74.5% 100N, with large blind spots) and so required more re-working than the previous zone. The initial detector rankings for the flame detectors in the vicinity of the zone are shown below, indicating that FD-008, FD-013 and FD-010 are all poorly positioned in comparison to FD-009.

Flame Detector Rankings for Zone PZ-L-002 ↔ → □ × Zone: Fire Zone: Zone PZ-L-002 ∨ Final Ranking Bias: ≥100N ≥200N								
							No	tes
Be	st	FD-009	14.9	9.6	1	2	1.2	1
		FD-011	8.1	10.1	2	1	1.8	2
		FD-012	5.3	4.3	3	5	3.4	3
		FD-010	3.4	4.4	4	4	4	4
		FD-013	3.1	7.8	5	3	4.6	5
Wo	orst	FD-008	2.2	4.1	6	6	6	6

The rankings for each detector for this zone are shown in Figure 19 below.




Figure 19. Results of the detector ranking tool on Zone PZ-L-002 showing best to least effective flame detectors

Improvements to the flame detector coverage for Zone PZ-L-002 were achieved by repositioning detectors FD-004 (previously deployed on Zone PZ-L-001), FD-008, FD-011 and FD-012, and reorienting FD-010 and FD-012. One additional flame detector was required – FD014. The new detector layout is shown on Figure 20.




Figure 20. New flame detector layout for PZ-L-002

The coverage of the new layout is over 90% 100N and nearly 70% 200N, well above the required performance criteria.

Fire Zone	Zero (0ooN)	1 or more (≥ 100N)	2 or more (≥ 200N)	3 or more (≥ 300N)
Zone PZ-L-002	8.9%	91.1%	69.3%	42.8%

Gas Detector Coverage

The gas detector risk grade for PZ-L-002 was downgraded to Risk Grade D, which resulted in the coverage now being calculated using a 10 meter diameter gas cloud instead of the original 5 meter gas cloud. Without any further changes in the gas detector layout, the coverage of the zone was recalculated as shown below, complying with the required performance criteria.

Gas Zone	Zero (0ooN)	1 or more (≥ 100N)	2 or more (≥ 200N)	3 or more (≥ 300N)
Zone PZ-L-002	0.1%	99.9%	88.3%	64.5%

Conclusions

The fire and gas detector layout on the P-12 platform was reviewed using Detect3D Fire and Gas Mapping software. Two zones were analyzed – PZ-L-001 and PZ-L-002.

The primary conclusions are as follows:

- The initial layout of fire and gas detectors did not provide coverage that was adequate to comply with the required performance criteria.
- Using the Detector Ranking Tool in Detect3D, the effectiveness of each detector was calculated.
- To improve the effectiveness of the flame detectors at the lowest possible cost, the detectors were first re-oriented, then repositioned if necessary, and as a final resort, new detectors were added.
- For both zones to comply with the required flame detector coverage:
 - \circ 4 of the 13 flame detectors required re-orienting alone
 - o 5 of the 13 flame detectors required re-positioning
 - 1 new flame detector was required
 - o 4 of the 13 flame detectors did not need any adjustment
- The gas detectors could also have been analyzed using the Detector Ranking Tool in Detect3D. However, instead the risk levels of the zones were inspected in more detail, and areas that were previously analyzed using a 5 meter gas cloud were instead analyzed with a 10 meter gas cloud, to account for a low risk level. This improved coverage to such an extent that no gas detectors required repositioning.
- Based on the adjustments in the report, both PZ-L-001 and PZ-L-002 can comply with the required performance target of 90% 100N and 50% 200N.

Appendix A – Revised Flame Detector Layout Work Pack

Note that the images for re-oriented or re-positioned detectors also include the laser aiming ray for additional validation.

F	lame Detector: FD-001 (reoriented)
Model	
Manufacturer :	Honeywell Analytics
Model :	SS4
Description :	High Sensitivity
Location	
X :	-47.37 [meters]
Y :	47.62 [meters]
Z :	21.53 [meters]
Orientation	
Azimuth :	-55°
Declination :	10°

Flame Detector: FD-002 (reoriented)	
Model	
Manufacturer :	Honeywell Analytics
Model :	SS4
Description :	High Sensitivity
Location	
X :	-36.1 [meters]
Υ:	40.91 [meters]
Z :	21.53 [meters]
Orientation	
Azimuth :	180°
Declination :	10°
Model	Flame Detector: FD-003

Model	
Manufacturer :	Honeywell Analytics
Model :	SS4
Description :	High Sensitivity
Location	
X :	-36.53 [meters]
Y :	35.02 [meters]
Z :	21.53 [meters]
Orientation	
Azimuth :	135°
Declination :	20°

Flame Detector: FD-005		
Model		
Manufacturer :	Honeywell Analytics	
Model :	SS4	
Description :	High Sensitivity	


Location

Location	
X :	-45.57 [meters]
Υ:	38.5 [meters]
Z :	24.27 [meters]
Orientation	
Azimuth :	45°
Declination :	60°

Flame Detector: FD-006	
Model	
Manufacturer :	Honeywell Analytics
Model :	SS4
Description :	High Sensitivity
Location	
X :	-36.23 [meters]
Υ:	42.58 [meters]
Ζ:	21.73 [meters]
Orientation	
Azimuth :	-135°
Declination :	30°

Flame Detector: FD-009	
Model	
Manufacturer :	Honeywell Analytics
Model :	SS4
Description :	High Sensitivity
Location	
X :	-56.14 [meters]
Υ:	29.96 [meters]
Ζ:	26.4 [meters]
Orientation	
Azimuth :	45°
Declination :	50°


	F	lame Detector: FD-010 (reoriented)
Model		
	1anufacturer :	Honeywell Analytics
	Model :	SS4
	Description :	High Sensitivity
Location	•	
	X :	-60.65 [meters]
	Y :	36.34 [meters]
	Z :	21.53 [meters]
Orientation		
	Azimuth :	0°
	Declination :	30°



	: Model Description	SS4 High Sensitivity
Location		
	X :	-60.58 [meters]
	Y :	44.45 [meters]
	Z :	21.53 [meters]
Orientation		
	Azimuth :	-45°
	Declination :	20°

Flame Detector: FD-013 (repositioned)	
Model	
Manufacturer :	Honeywell Analytics
Model :	SS4
Description :	High Sensitivity
Location	
X :	-48.72 [meters]
Υ:	36.57 [meters]
Z :	24.63 [meters]
Orientation	
Azimuth :	180°
Declination :	40°


Flame Detector: FD-011 (repositioned)	
Model	
Manufacturer :	Honeywell Analytics
Model :	SS4
Description :	High Sensitivity
Location X :	-55.02 [meters]
×. Y:	46.81 [meters]
Z:	25.09 [meters]
Orientation	
Azimuth :	-90°
Declination :	45°
Flame Detector: FD-014 (new detector)	



	: Model Description	SS4 High Sensitivity
Location		
	X :	-52.99 [meters]
	Y :	31.05 [meters]
	Z :	24.29 [meters]
Orientation		
	Azimuth :	90°
	Declination :	45°

Flame Detector: FD-004 (repositioned)		
Model		
Manufacturer :	Honeywell Analytics	
Model :	SS4	
Description :	High Sensitivity	
Location		
X :	-60.92 [meters]	
Y :	40.8 [meters]	
Z :	21.56 [meters]	
Orientation		
Azimuth :	0°	
Declination :	0°	

Flame Detector: FD-008 (repositioned)		
Model		
Manufacturer :	Honeywell Analytics	
Model :	SS4	
Description :	High Sensitivity	
Location		
X :	-51.47 [meters]	
Υ:	36.99 [meters]	
Ζ:	23.78 [meters]	
Orientation		
Azimuth :	90°	
Declination :	60°	
Decimation .		
Elame Detector: ED-007 (repositioned)		



	: Model Description	SS4 High Sensitivity
Location		
	X :	-41.76 [meters]
	Y :	47.58 [meters]
	Z :	24.38 [meters]
Orientation		
	Azimuth :	-90°
	Declination :	60°